Introduction

The Levenseat Renewable Energy (LREL) waste treatment facility consists of an advanced materials recovery facility and a combined heat and power plant, designed to recover recyclable material from black waste and maximise diversion from landfill.

Once all efforts have been made to recover recyclable material from waste streams, the next best option is to recover energy from the remaining waste. This not only means we are recovering value from waste; we are also diverting waste from landfill and helping to contribute to Scotland's renewable energy targets.

Key Facts

12.5MW

Electricity Generated

Equivalent to the needs of

25, 000 Homes

215, 000 tonnes

Processing Capacity

Interesting Facts

The LREL facility is designed to process residual waste, otherwise known as black bin waste, waste that householders have deemed to be unrecyclable, yet we are able to recover and recycle on average 20% of the material received.

84, 000 Aluminium cans recovered

224,875 Plastic bottles recovered


Other materials recovered include WEEE from electrical equipment, organic fines that are sent for composting, and ferrous metals in the form of pots and pans etc.

*based on 2020 annual statistics

Step 1: Recovery of Recyclates
Materials such as wood, cardboard, ferrous metals, non-ferrous metals, mixed plastics, and inerts are all recovered and diverted back into the manufacturing or construction industries.

Step 2: Fuel Preparation
The remaining waste is prepared into a fuel known as Refused Deriver Fuel. This fuel is made to a specific, detailed standard to ensure a clean and efficient conversion process and to minimise production of ash and other by-products

Step 3: Energy Recovery
Our Power Plant provides an environmentally responsible means of producing reliable baseload electricity. The Plant uses non-recyclable waste as a fuel, reducing our reliance on fossil fuels, the need for landfill and cutting emissions.



Emissions Monitoring

Emissions are monitored directly by our Continuous Emissions Monitoring System (CEMS). This system is fitted inside the stack so it monitors the flue gas before it is released into the atmosphere.

The majority of our emissions are compounds of normal air like steam, oxygen, nitrogen and carbon dioxide. For the very small remainder of emissions, they go through a sophisticated treatment process that ensures emissions remain well below all relevant standards.


In addition to providing information to SEPA for regulatory compliance, the CEMS also allows the Power Plant team to monitor the processes. The data provided by the monitoring systems gives useful feedback on how the processes are operating, thereby allowing the team to safely and efficiently run the plant.

	Permitted levels mg/Nm3	
	Daily	**30 min max average**
Nitrogen Oxide (NO_x)	200	400
Carbon Monoxide (CO)	50	100
Sulphur Dioxide (SO_2)	50	200
Hydrogen Chloride (HCl)	10	60
Ammonia (NH_3)	10	
Total Organic Carbon (TOC)	10	20
Particulates	10	30

Please see below for this months report


Learn more at www.lrel.co.uk

AUGUST 2023 DAILY AVERAGE CEMS REPORT



	01-Aug	02-Aug	03-Aug	04-Aug	05-Aug	06-Aug	07-Aug	08-Aug	09-Aug	10-Aug	11-Aug	12-Aug	13-Aug	14-Aug	15-Aug	16-Aug	17-Aug	18-Aug	19-Aug	20-Aug	21-Aug	22-Aug	23-Aug	24-Aug	25-Aug	26-Aug	27-Aug	28-Aug	29-Aug	30-Aug	31-Aug
NOx 30m Max	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	119.6	116.6	126.0	131.9	130.9	120.3	127.1	88.30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	157.1	150.3	148.8	139.4
CO 30m Max	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	12.80	11.30	20.30	185.1	91.70	64.40	23.10	44.40	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	57.30	57.30	72.30	13.80
SO2 30m Max	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	6.500	7.700	8.300	8.000	8.400	8.500	8.500	8.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	7.200	7.500	7.900	5.800
HCl 30m Max	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2.700	12.50	7.700	7.200	7.200	7.700	6.700	5.700	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	8.400	7.700	8.100	8.200
NH3 30m Max	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.500	1.300	1.700	1.500	2.200	3.000	2.100	1.700	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2.400	3.200	2.000	1.300
TOC 30m Max	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.600	1.600	1.600	7.000	1.700	1.700	1.600	1.600	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	2.500	4.900	2.200	0.900
Particulate Matter 30m Max	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	20.20	15.30	0.600	0.300	0.100	0.200	0.300	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	5.500	0.500	5.100	0.500

AUGUST 2023 DAILY AVERAGE CEMS REPORT



	01-Aug	02-Aug	03-Aug	04-Aug	05-Aug	06-Aug	07-Aug	08-Aug	09-Aug	10-Aug	11-Aug	12-Aug	13-Aug	14-Aug	15-Aug	16-Aug	17-Aug	18-Aug	19-Aug	20-Aug	21-Aug	22-Aug	23-Aug	24-Aug	25-Aug	26-Aug	27-Aug	28-Aug	29-Aug	30-Aug	31-Aug
NOx Daily Mean	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	107.6	103.9	108.3	119.2	112.1	106.2	112.5	88.30	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	111.7	105.3	129.1	116.9
CO Daily Mean	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	8.200	8.500	10.60	17.60	21.30	18.60	10.90	44.40	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	15.20	17.60	12.80	9.400
SO2 Daily Mean	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	6.300	6.900	7.400	7.300	7.600	7.600	7.800	8.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	6.800	7.000	6.600	5.400
HCl Daily Mean	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.700	3.500	6.200	5.700	6.500	6.500	6.100	5.700	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	5.400	3.700	5.700	7.000
NH3 Daily Mean	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.200	0.800	1.000	0.900	1.500	1.800	1.300	1.700	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.400	1.500	0.700	0.800
TOC Daily Mean	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.500	1.400	1.500	1.600	1.500	1.500	1.500	1.600	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.500	1.600	1.200	0.800
Particulate Matter Mean	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	8.100	3.500	0.100	0.100	0.000	0.100	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.800	0.000	0.100	0.000